

PHONE : (C) 26598588 / 95
(P) 26598589
FAX : 022- 26598587
E-Mail : cetrpl@mahatransco.in



Office of the Chief Engineer
Transmission Planning Deptt.
'Prakashganga', MSETCL
Plot no. C-19, E-Block,
Bandra Kurla complex, Bandra (E)
Mumbai - 400051

MSETCL/CO/TR.PR./D&E-S2/Vendor Approval/

No 13404 - 5 SEP 2011

To
✓ M/s Venson Electric Pvt. Ltd.,
#331, 9th Cross, 4th phase,
Peenya Industrial area,
Bangalore-560058.

102 SEP 3 2011

Sub: Vendor Approval for supply of Control and Relay Panels for upto 220kV System for MSETCL's various projects.

Ref: 1. Your letter No. VEPL/PNK/APPROVAL/2011-Dated 09/07/2011.

Dear Sirs,

We have for reference your aforesaid letter vide which you have requested us to accept you as an as an approved vendor for supply of Control & Relay panels for EHV substations/switchyards of MSETCL. Various documents including undertaking, credentials etc. were also furnished by you alongwith aforesaid letter.

Based on the documents furnished by you, we are pleased to inform that your request for considering you, i.e. **M/s Venson Electric Pvt. Ltd., as an approved vendor for supply of Control & Relay panels (for upto 220kV system), for MSETCL's EHV switchyards attached to ORC consumers/co-generation projects etc. has been accepted.** It may, however, be noted that you shall use all numerical relays and Automation system of ABB/Areva/ER/SEL/Siemens/GE make and auxiliary & trip relays of ABB/Areva/ER make. In case of any make other than above, the same shall be subject to specific approval.

It may also be noted that this acceptance does not automatically qualify you against any of the Tenders floated/to be floated by MSETCL, where you shall conform/fulfill all technical and commercial terms and conditions of the tender to emerge as qualified bidder.

Yours faithfully,

Chief Engineer (Trans. Projects)