

ಕರ್ನಾಟಕ ವಿದ್ಯುತ್ ಪ್ರಸಾರಣ ನಿಗಮ ನಿಯಮಿತ

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED**

PH NO.: 08338 – 275173 FAX NO: 08338 – 275173 Email- eetlss\_ckd@rediffmail.com

OFFICE OF THE  
EXECUTIVE ENGINEER(ELE)  
T L & S S DIVISION KPTCL  
VIDYUTH NAGAR  
CHIKKODI-561201



ರವರ ಕಛೇರಿ,  
ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು(ಬಿ)  
ಪ್ರಸಾರಣ ಮಾರ್ಗ & ಉಪಕೇಂದ್ರ ವಿಭಾಗ,  
ಕವಿಪ್ರಸನ್ನಿ,  
ವಿದ್ಯುತ್ ನಗರ, ಚಿಕ್ಕೋಡಿ-591201

ಸಂಖ್ಯೆ: ಬಿ /ಕಾ.ನಿ.ಇಂ(ಬಿ)/ಪ್ರ.ಮಾ.ಉ.ಕೇ/ ತಾ/ಕ- /

ಬಿನಾಂಕ :

**PERFORMANCE CERTIFICATE  
TO WHOMSOEVER IT MAY CONCERN**

This is to certify that M/s. VENSON ELECTRIC PVT LTD, No.331, 9<sup>th</sup> Cross, 4<sup>th</sup> Phase, Peenya Industrial Area, Bangalore-560058 has supplied 22 No's of panel with following configuration.

Sl.No	Description	Qty
1	Control and relay penal for 110/11KV transformer	2 No's
2	Control and relay penal for 110/33KV transformer	1 No
3	Control and relay penal for 110KV line	1 No
4	Control and relay penal for 33KV line	2 No's
5	Control and relay penal for 11KV incomer (outdoor type)	2 No's
6	Control and relay penal for 11KV outgoing (outdoor type)	9 No's
7	Control and relay penal for 11KV capacitor bank (outdoor type)	2 No's
8	Remote control desk with annunciation penal (indoor type)	2 No's

We have commissioned the panel in the year 31.08.2007 and the same is working satisfactorily with JVS make relays (TCSR Auxiliary, tripping and IDMT relays) since commissioning.

And we are happy with the quality and performance of the panel.

With regards,

Yours Faithfully,

*[Signature]*  
Executive Engineer (E)  
TL & SS Division KPTCL,

Chikkodi

ಕಾರ್ಯ ನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರು (ಎ)  
ಪ್ರಸಾರಣ ಮಾರ್ಗ ಮತ್ತು ಉಪಕೇಂದ್ರ ವಿಭಾಗ  
ಕ.ವಿ.ಪ್ರ.ನಿ.ನಿ., ಚಿಕ್ಕೋಡಿ.

Copy to:

1. Nodal officer 110KV MUSS Chikkodi.

of  
Assistant Engineer  
10 KV MUSS KPTCL

PERFORMANCE

CERTIFICATE

Mantur


TO WHOMSOEVER IT MAY CONCERN

This is to certify that M/s Venson Electric Pvt Ltd. No 331, 9<sup>th</sup> cross, 4<sup>th</sup> ph. penya Industrial Area. B'lore - 560058 has supplied  
... No of panel with following Configuration

- |    |  |                                     |         |
|----|--|-------------------------------------|---------|
| 1) | Control & Relay panel                                  | 10/11 kv TFR                        | - 1 No  |
| 2) | - do -   | 11/33 kv TFR                        | - 1 No  |
| 3) | - do -   | 10 kv line                          | - 1 No  |
| 4) | - do -   | 33 kv. line                         | - 2 Nos |
| 5) | - do -   | 11 kv. incomer<br>(Cout door type)  | - 1 No  |
| 6) | - do -   | 11 kv out going<br>(Cout door type) | - 4 No  |
| 7) | - do -   | Capacitor Bank                      | - 1 No  |
| 8) | Remote Control Desk with annunciator<br>(In door type) |                                     | - 1 No  |

We have Commissioned the panel in the year 2006 and the same is working satisfactory since Commissioning. And we are happy with the quality and performance of the panel.

With Regards

  
Assistant Engineer  
10 KV MUSS KPTCL  
Mantur

Place - Mantur

Date - 2/2/2012





Telephone No: 08384 – 226998

e-mail : eetlss.sirsi@gmail.com

Fax : 08384 - 228153

## KARNATAKA POWER TRANSMISSION CORPORATION LIMITED

No. EEE/ TLSS/ SRS/AE(T)/ F-22/ 48 79

Office of the,  
Executive Engineer (El.),  
TL & SS Division, Sirsi.

Date : 04.02.2012

### PERFORMANCE REPORT

This is to certify that **M/s. VENSON ELECTRIC PVT. LTD., Bangalore** has supplied 220/110kV Transformer (01 No.), 110kV Lines (04 Nos.) & 110kV Bus Coupler (01 No.) control & relay panels with Auxiliary & tripping relays of JVS Electronics PVT. LTD. make in the year 2007-08 to 220kV R/S, Esale, Sirsi. Out of 06 Nos. of control & relay panels only 220/110kV transformer control & relay panel has been test charged on 30.08.2007 & kept open & again re-commissioned on 29.05.2009. Till today Control & Relay panel of 220/110kV Transformer is in service & giving satisfactory performance. But remaining Control & Relay panels of 110kV Lines & 110kV Bus Coupler have not commissioned.

We are satisfied with the performance of Control & Relay panel of 220/110kV Transformer of M/s. VENSON ELECTRIC PVT. LTD., Bangalore. This performance report issued as per the request of M/s. VENSON ELECTRIC PVT. LTD., Bangalore vide letter No.:VEPL/KPTCL/AUD dtd: 31.01.2012.

  
Executive Engineer (Elect.),  
TL & SS Division KPTCL, Sirsi.

To whom it may concern.