



M. P. POWER TRANSMISSION COMPANY LTD.

(FULLY OWNED BY GOVERNMENT OF MADHYA PRADESH)

No.04-01/3495-4/SII/ 849

Dt:- 1 FEB 2007

To

M/s Venson Electric Pvt. Ltd.,
No.331, 9th Cross, Fourth Phase,
Peenya Industrial Area,
BANGALORE - 560 058.

Fax No. 080 - 28361335

Kind attention : Mr. A. Panish, Manager (Marketing)

Sub:- Performance of C&R panels and numerical relays type GRZ and GRT of Toshiba make and backup protection relay of JVS make supplied against our ADB contract nos. 04-01/3495-4 dt.26/12/2002 and 3640-2 dtd 05/05/2005.

Ref :- Your letters dtd 2/11/06 & 5/1/07.

Dear Sir,

We hereby confirm that following categories of C&R panels were supplied by M/s Venson against two of our ADB contracts mentioned above.

Sr. No.	P.O. No. & Date	Description	Qty (nos)
1	04-01/ADB(1869)/MPSEB/ TR-04/3495-4 dtd 26/12/2002	1) C&R panel (Type A) for 132KV Feeders	50
		2) C&R panel (Type B) for 132KV side of 220KV Transformers	05
		3)C&R panel (Type C) for protection of 132/33KV transformers	20
		4) C&R panel (Type D) for protection of 132KV Bus coupler	10
2	04-01/ADB(1869)/MPSEB/ TR-26/3640-2/SII dt 05.05.05	1) C&R panels (Type A) for 220KV Feeders	18
		2) C&R panels (Type B) for protection of Bus Tie	02
		3) Numerical Distance Protection Relays (Type GRZ-100) loose	05

It is hereby confirmed that C&R panels supplied against ADB contract dtd 26/12/02 have been in service for more than two years and those against contract dtd 5/5/05 for more than one year and that performance of numerical distance and differential protection relays GRZ-100 and GRT-100 and also of JVS make numerical backup protection relay type JNP-098, has been found to be satisfactory in above panels.

Yours sincerely,

CHIEF ENGINEER (PLANNING)
MPPTCL : JABALPUR